



Product Service

Attestation of Conformity

No. N8A 18 04 03649 003

**Holder of Certificate: Zhejiang CHINT
Instrument & Meter Co., Ltd.**Wenzhou Bridge Industrial Zone
325603 Yueqing
PEOPLE'S REPUBLIC OF CHINA**Product: Electronic measuring equipment
(Three-Phase Smart Meter)****Model(s): DTSU666 5(80), DTSU666 1.5(6),
DSSU666 5(80), DSSU666 1.5(6)****Parameters:**

Rating:	
DTSU666 5(80):	3X230/400V, 50/60Hz, max. 80A;
DTSU666 1.5(6):	3X230/400V, 50/60Hz, max. 6A;
DSSU666 5(80):	3X400V, 50/60Hz, max. 80A;
DSSU666 1.5(6):	3X400V, 50/60Hz, max. 6A
Measurement Categories:	II
Overtoltage category:	II
Pollution degree:	2
Means of protection:	Class II

Tested according to: EN 61010-1:2010
EN 61010-2-030:2010

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 64105180082801**Date,** 2018-04-12

(Frank Zhu)


CE After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1